

DAILY CONSTRUCTION INSPECTION REPORT

Copies Distributed To: RLV FILE MSW RMS DC DL	CITY OF GROTON, CONN DEPT OF UTILITIES	Date: 7/9/14	No. 59
		Work Order: 27182SW	
Contractor: G. Donovan Associates Inc		Weather: Clr	Temp:80's
Project: Construction of Booster Pumping Station		Location:	Route No.
To Serve Aljen Heights Water Extension Phase 1B Contract 2013-03 REBID		Holmberg Tank	

WORK DONE BY CONTRACTOR

United Concrete personnel ran pumps to flush 16" & 12" water mains in easement from pump station to Naomi Dr. Also, flushed 8" & 10" water mains on Tuckers Run to Avery Hill Road.

Electricians worked inside station

CONTRACTOR'S FORCE AND EQUIPMENT

SUMMARY OF DELIVERY SLIPS

Sup't		Item		Source	No Loads	Qty
1	Backhoe	1	Pump			
	Bulldozer		Roller			
2	Compressor		Saw-Power			
	Crane		Shovel			
	Grade		Trucks			
	Loader		Trench Box			
	Mixer-Conc.		Misc. Equip			
	Mixer-Paver					
	Excavator					
	Hoe-Ram					

Original Calendar Days - 150 Used - 287

Official Visitors to Job

WORK DONE BY OTHERS

Dept or Company	Description of Work	Name	Title
United Concrete	Electricians		
	Greg Jobs		

Inspection Force

	Name	Title
	David L Corallino	Project Manager
Contractors	Inspector	
Hours of Work		