



GROTON UTILITIES

At Your Service

Michael Zakutansky
Groton Utilities
295 Meridian St.
Groton, CT 06340

July 22, 2015

Mr. Steven Banks
Chief Plant Operator
Town of Ledyard WPCA
82 Town Farm Road
Ledyard, CT 06339

Dear Steve,

On July 15, 2015 I conducted a check for electrical power on your equipment slated for demolition. A review of the available plans shows this equipment was feed from a riser pole behind the existing office, this riser no longer exists. The two Dorr-Oliver Clarigesters , two trickling filters and the two small pumping stations were each checked and found to have no electricity feeding them.

I am willing to meet with your demolition contractor, if they should wish to discuss my findings or have the tests repeated in their presence.

Sincerely,

Michael Zakutansky
Senior Electrician

CC: Randall Surprenant : GU
Project Management : GU
File